

PATRICIA A. PESHKA

PURCHASING AGENT



SCOTT AVEDISIAN

MAYOR

CITY OF WARWICK

**PURCHASING DIVISION
3275 POST ROAD
WARWICK, RHODE ISLAND 02886
TEL (401) 738-2000 EXT. 6240
FAX (401) 737-2364**

To: All Prospective Bidders

From: Patricia A. Peshka, Purchasing Agent

Date: October 6, 2016

Re: **Bid2017-128 Cooper Building Fire Alarm Upgrades Phase IV**

Addendum #2

=====

Please be advised that the information provided comprises Addendum # 2.

The bid opening remains on Wednesday, October 12, 2016 at 11 AM in the Lower Level Conference Room at City Hall.

Thank you for your interest in this project.

TO: All Bidders

FROM: Joseph J. Watson, PE

SUBJECT: Bid #2017-128 Fire Alarm Upgrades Cooper Building

DATE: October 5, 2016

CC: Joseph Blake – City of Warwick

Please include the following clarifications to the City of Warwick Phase IV Fire Alarm plans (Bid #2017-128). This document shall supplement Construction Documents dated August 26, 2016.

The following are from the written questions received.

1. Is the contractor responsible for submitting drawings and paying the fee for approval to the fire department? If so, will the drawing approval wait time be added to the 90 day schedule?

The Contractor is responsible for all permits and fees for approval. All time required for permit approval is included in the 90 day schedule.

2. Is the contractor responsible to provide a one year quarterly testing contract at the completion of the project?

The Contractor is not responsible for inspection, testing and maintenance of the system following the successful acceptance testing of the system.

3. It appears in the bid request that there are three pages that should be included. Page 2, 3 & 25 as well as the Bid Bond.

Correct.

4. Will any permit fees be required to be paid or will permit fees be waived?

See response to Item #1.

5. It is required to perform a Contractor Pre-test, a Pre-test with JH Engineer and the final test with the authorities. Please confirm that the fire alarm manufactures vendor should be at all three of these tests?

Confirmed, the vendor shall be present at all tests.

All bidders must acknowledge acceptance of this addendum in their bid.

Please do not hesitate to contact our office with any questions.